Arizona Department of Weights and Measures

Vapor Recovery Alert No. 15

Installation of the OPW 61SO-EVR in non-vaulted systems

March 14, 2005

The Department of Weights and Measures is issuing this *Vapor Recovery Alert* to inform the Registered Service Agency (RSA) community that the Department is extending its approval of the use of the OPW 61SO-EVR to non-vaulted systems. The Department has determined that OPW has addressed to the satisfaction of the Department the concerns the Department had with the OPW 61SO this new equipment can therefore, be used for overfill protection in non-vaulted systems, and is effective as of the date of this Vapor Alert. This approval is also conditional upon the proper installation of the equipment by a certified OPW installer. Any equipment not meeting these conditions will be tagged out of service until such time as the Department can ensure the system integrity. It is also noted that the 3 inch ball float valve must be removed or replaced with a smaller 2 inch ball float valve like the OPW 53VML-0065 or something comparable as recommended by the manufacture.